



ELECTRICAL TURN ON CHECK LIST

DATE:

INSPECTOR:

DR #:

PERMIT #:

ADDRESS:

SERVICE SIZE AND LOCATION:

ITEM	YES	NO	N/A
Drip loop is a minimum of 10' above surface.			
At least one driven ground rod inside or outside the house.			
Grounding conductor connected to either meter base or panelboard.			
All metal water bonded to ground.			
All metal gas piping bonded to the ground			
Bonding jumper is installed across water meter.			
Each breaker/fuse serves only one circuit. (no more than one conductor on a breaker or fuse)			
No open holes in covers or panelboard cabinets			
Only one wire in each main lug.			
Overcurrent protection properly sized for conductors			
Service entrance cable is not deteriorated.			
Service entrance cable is properly secured to building.			
Service entrance conduits properly secured to the building			
Able to close meter box with no holes.			

IMPORTANT NOTICES

- 1) ALL ITEMS MARKED AS "NO" MUST BE CORRECTED PRIOR TO ELECTRICAL SERVICE BEING TURNED ON.
- 2) A NEW PERMIT MUST BE OBTAINED AND A RE-INSPECTION CONDUCTED PRIOR TO THE SERVICE BEING TURNED ON.
- 3) TAKE THIS CHECK LIST WITH YOU TO THE PERMIT OFFICE WHEN YOU GET YOUR NEW PERMIT.
- 4) YOU MUST HAVE THIS CHECK LIST AVAILABLE FOR THE INSPECTOR DURING THE RE-INSPECTION.